


## Chapter 4 Sequential Instructions

The sequential instructions of FBs-PLC shown in this chapter are also listed in section 3.1. Please refer to Chapter 1, "PLC Ladder diagram and the Coding rules of Mnemonic instruction", for the coding rules in applying those instructions. In this chapter, we only introduce the applicable operands, ranges and element characteristics, functionality.


### 4.1 Valid Operand of Sequential Instructions

Instruction \ Operands Ranges	X	Y	M	SM	S	T	C	TR	OPEN	SHORT
	X0   X255	Y0   Y255	M0   M1911	M1912   M2001	S0   S999	T0   T255	C0   C255	TR0   TR39	—	—
ORG	○	○	○	○	○	○	○		○	○
ORG NOT	○	○	○	○	○	○	○			
ORG TU	○	○	○	○*	○	○	○			
ORG TD	○	○	○	○*	○	○	○			
LD	○	○	○	○	○	○	○	○	○	○
LD NOT	○	○	○	○	○	○	○			
LD TU	○	○	○	○*	○	○	○			
LD TD	○	○	○	○*	○	○	○			
AND	○	○	○	○	○	○	○		○	○
AND NOT	○	○	○	○	○	○	○			
AND TU	○	○	○	○*	○	○	○			
AND TD	○	○	○	○*	○	○	○			
OR	○	○	○	○	○	○	○		○	○
OR NOT	○	○	○	○	○	○	○			
OR TU	○	○	○	○*	○	○	○			
OR TD	○	○	○	○*	○	○	○			
OUT		○	○	○*	○			○		
OUT NOT		○	○	○*	○					
OUT L		○								
ANDLD	—									
ORLD	—									
TU	—									
TD	—									
NOT	—									
OUTS		○	○	○*	○					
OUTR		○	○	○*	○					

※For the relays marked with a  symbol in the special relay table ( please refer to section 2.3 ) is write prohibited. In addition, TU and TD contacts are not supported for those relays as well. The operands marked with a ‘\*\*’ symbol in the table shown above should exclude those special relays.

## 4.2 Element Description

### 4.2.1 Characteristics of A,B,TU and TD Contacts




The waveform shown above reveals the function of A, B, TU and TD elements by exercising the external input X0 from OFF to ON then OFF.

- TU (Transition Up): This is the “Transition Up Contact”. Only a rising edge (0→1) of the referenced signal will turn on this element for one scan time.
- TD (Transition Down): This is the “Transition Down Contact”. Only a falling edge (1→0) of the referenced signal will turn on this element for one scan time.
- TU and TD contact will work normally as described above if the change of the status of the valid referenced operands listed in the “Valid Range of the Operand of Sequential instructions” table are not driven by the function instructions.

Remark: For TU(TD) elements which operand is of relay will turn on after the first time the corresponding relay get driven from 0 to 1(1 to 0). When the next time the corresponding relay get driven from 1 to 1(0 to 0) the TD(TU) element will turn OFF. Care should be taken while there is a multiple coil usage situation existed in the ladder program. This situation can be best illustrated at below. In the waveform we can see Y0 TU element only turn on between ⑥ and ⑦ time which only the Y0 TU elements existed between rung 1 and rung 2 can detect the Y0 rising edge, while other Y0 TU elements out side these two ladder rungs will never aware the occurrence of the rising edge. For the relays do not have the multiple coil usage in ladder program, The ON status of corresponding TU or TD element can be sustained for one scan time, but for relays which contrary to above, the turn on time will shorter than 1 scan time as illustrated at below.

Ladder Diagram	Mnemonic code
	<pre> ORG   X 0 -----(a) OUT   Y 0 -----(b) OUT   Y 1 -----(c) ORG   X 1 -----(d) OUT   Y 0 -----(e) </pre>




[A]: The internal accumulator of PLC


- Besides the TU/TD instructions which can detect the status change of reference operand, FBs-PLC also provides the instructions to detect the change of node status (power flow). For details please refer the descriptions of FUN4 (DIFU) and FUN5 (DIFD) instructions.

#### 4.2.2 OPEN and SHORT Contact

The status of OPEN and SHORT contact are fixed and can't be changed by any ladder instructions. Those two contacts are mainly used in the places of the Ladder Diagram where fixed contact statuses are required, such as the place where the input of an application instruction is used to select the mode. The sample program shown below gives an example of configuring an Up/Down counter (UDCTR) to an Up counter by using the SHORT contact.




FUN7 is the UDCTR function. While rising edge of CK input occur, FUN7 will count up if the U/D status is 1 or count down if the U/D status is 0. The example shown above, U/D status is fixed at 1 since U/D is directly connected from the origin-line to a SHORT contact, therefore FUN7 becomes an Up counter. On the contrary, if the U/D input of FUN7 is connected with an OPEN contact from the origin-line, the FUN7 becomes a DOWN counter.



### 4.2.3 Output Coil and Inverse Output Coil

Output Coil writes the node status into an operand specified by the coil instruction. Invert Output Coil writes the complement status of node status into an operand specified by the coil instruction. The characteristics depicts at below.



### 4.2.4 Retentive Output Coil


The coil element can be categorized into two types, namely Retentive and Non Retentive. For example, M0~M799 can be specified as the Retentive coils and M800~M1399 can be specified as the Non Retentive coils. One way to categorize the relay type is to divide the relays into groups. Though this method is simple but for the most applications the coils needed to be retentive may be in a random order. FBs-PLC allows user to set the retentive status of coil individually. When input the program with mnemonics instructions, if put an “L” after the OUT instruction can declare this specific relay as retentive output. This can be shown in the diagram below.



From the above example, if turn the X0 "ON" then "OFF", Y0 will keep at "ON". When change the PLC state from RUN to STOP then RUN or turn the power off then on, the Y0 still keep at ON state. But if use the OUT Y0 instruction instead of the OUT L Y0 , Y0 status will be OFF.

### 4.2.5 Set Coil and Reset Coil

Set Coil writes 1 into an operand specified. Reset Coil writes 0 into an operand specified. The characteristics depicts at below.



### 4.3 Node Operation Instructions

A node is the connection between elements in a ladder diagram consisting of sequential instruction elements (please refer to Section 1.2). There are four instructions dedicated for node status operation in FBs-PLC. The two instructions, "OUT TR" and "LD TR", have been discussed in Section 1.6 of this manual. Using the diagram below, the three node operation instructions NOT, TU and TD, are illustrated.

